



059, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64
Ph : 8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5)

Date: 12-05-2022

Name of Work : "Augmental of water supply through bowell, network of pipelines and ground water recharge facilities in various layout of harohalli, Nagenahalli, kenchenhalli, Anantapura, Doddabettahalli and chikkabettahalli village limits in ward no 02,03 of yelahanka Division (PACKAGE No-16)"

Client: Bruhat Bangalore Mahanagara Palike (BBMP), Yelahanka Zone, Bengaluru.

Contractor: Sri. Gopi Reddy

Customer Reference: BBMP/EE/YNK.D/EPMT-14/AGI/07/2022-23

Source of Sample: Sample supplied by Agency

Sample Condition: Satisfactory

Date of Receipt: 12-05-2022

Sample Type: C.C Road

Sample Type/Size: 150x150x150 mm

Sample Grade/ Age: M30/ 7 Days Compressive Strength

Date of Test: 19-05-2022

Sl. No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specfication	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm ²	N/mm ²
1	C.C Road	M30	12-05-2022	19-05-2022	150x150x150	22500	463	21.36	21.42
2	C.C Road	M30	12-05-2022	19-05-2022	150x150x150	22500	473	22.54	
3	C.C Road	M30	12-05-2022	19-05-2022	150x150x150	22500	470	20.36	

Remarks :



Asst. Executive Engineer
Yelahanka Sub. Division
(BBMP Yak Zn)
Yelahanka, Bangalore

Asst. Executive Engineer
Yelahanka Sub. Division
(BBMP Yak Zn)
Yelahanka, Bangalore

Signature of Asst. Executive Engineer

Signature of Asst. Executive Engineer
Yelahanka Sub. Division
(BBMP Yak Zn)
Yelahanka, Bangalore



9, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64

8048505503 | Email : artnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5) Date: 10-06-2022

Name of Work : "Augmental of water supply through bowell, network of pipelines and ground water recharge facilities in various layout of harohalli, Nagenahalli, kenchenhalli, Mantapura, Doddabettahalli and chikkabettahalli village limits in ward no 02,03 of Yelahanka Division (PACKAGE No-16)"

Client	Bruhat Bengaluru Mahanagara Palike (BBMP), Yelahanka Zone, Bengaluru.
Contractor	Sri. Gopi Reddy
Customer Reference	BBMP/EE/YNK.D/EPMT-14/AG/07/2022-23
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Receipt	13-05-2022
Sample Type	C.C Road
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	M30/ 28 Days Compressive Strength
Date of Test	10-06-2022

Sl. No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification mm	Cross sectional area Sq.mm	Weight of the sample kg	Maximum Load in KN	Compressive Strength N/mm ²	Average Compressive Strength N/mm ²
1	C.C Road	M30	13-05-2022	10-06-2022	150x150x150	22500	8.72	682	32.58	32.08
2	C.C Road	M30	13-05-2022	10-06-2022	150x150x150	22500	8.87	695	31.89	
3	C.C Road	M30	13-05-2022	10-06-2022	150x150x150	22500	8.62	686	31.78	

Remarks :



Asst. Executive Engineer
Yelahanka Sub. Division
(BBMP Ynk Zn)
Yelahanka, Bangalore

R1
10-03-22

ಸಹಾಯಕ ಮುಖ್ಯಮಂತ್ರಿ
ಮುಖ್ಯಮಂತ್ರಿ
ಕೆ.ಎಂ.ಕೆ. ಶಿರಡಿಗಾರ್-108

ARTN ASSOCIATES

Modern Construction Solutions

9, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64

8048505503 | Email - aartnassociates@gmail.com



IS: 516-1959 (Method of tests for strength of Concrete C1.5)					Date: 07-06-2022				
Name of Work : "Augmental of water supply through bowell, network of pipelines and ground water charge facilities in various layout of harohalli, Nagenahalli, kenchenhalli, Anantapura , Doddabettahalli and chikkabettahalli village limits in ward no 02,03 of yelahanka Division (PACKAGE No-16)"									
Client	Bruhat Bangalore Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.								
Contractor	Sri. Gopi Reddy								
Customer Reference	BBMP/EE/YNK.D/EPMT-14/AG/07/2022-23								
Source of Sample	Sample supplied by Agency								
Sample Condition	Satisfactory								
Date of Receipt	10-05-2022								
Sample Type	C.C Road								
Sample Type/Size	150x150x150 mm								
Sample Grade/ Age	1:5:10/ 28 Days Compressive Strength								
Date of Test	07-06-2022								
Location									
Sl. No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm ²	N/mm ²
1	C.C Road	DLC(1:5:10)	10-05-2022	07-06-2022	150x150x150	22500	700	11.4	11.70
2	C.C Road	DLC(1:5:10)	10-05-2022	07-06-2022	150x150x150	22500	694	12.4	
3	C.C Road	DLC(1:5:10)	10-05-2022	07-06-2022	150x150x150	22500	697	11.4	
Remarks :									



Asst. Executive Engineer
Yelahanka Sub. Division
(BBMP Ynk. Zn)
Yelahanka, Bangalore

ಶಾಖಾ ಮುಖ್ಯಸ್ಥರು
ಮುಖ್ಯಸ್ಥರ ಕಛೇರಿ
ಬಿ.ಬಿ.ಎಂ.ಸಿ. ಬೆಂಗಳೂರು-106.

ARTN ASSOCIATES

Modern Construction Solutions



59, MIG-A Sector, Opp. Railwheel Factory,
Yelahanka New Town, Bangalore - 64

8048505503 | Email : aartnassociates@gmail.com

Test Report of Cement Concrete Cubes

IS: 516-1959 (Method of tests for strength of Concrete C1.5)


Date: 07-06-2022

Name of Work : "Augmental of water supply through bowell, network of pipelines and ground water recharge facilities in various layout of harohalli, Nagenahalli, kenchenhalli, Anantapura , Doddabettahalli and chikkabettahalli village limits in ward no 02,03 of yelahanka Division PACKAGE No-16)"

Client	Bruhat Bengaluru Mahanagara Palike (BBMP) , Yelahanka Zone, Bengaluru.
Contractor	Sri. Gopi Reddy
Customer Reference	BBMP/EE/YNK.D/EPMT-14/AG/07/2022-23
Source of Sample	Sample supplied by Agency
Sample Condition	Satisfactory
Date of Receipt	10-05-2022
Sample Type	C.C Road
Sample Type/Size	150x150x150 mm
Sample Grade/ Age	1:5:10/ 28 Days Compressive Strength
Date of Test	07-06-2022
Location	

Sl No.	Identification Mark	Grade of Concrete	Date of Casting	Date of Trsting	Dimension of Specification	Cross sectional area	Maximum Load in	Compressive Strength	Average Compressive Strength
					mm	Sq.mm	KN	N/mm ²	N/mm ²
1	C.C Road	DLC(1:5:10)	10-05-2022	07-06-2022	150x150x150	22500	701	11.3	11.48
2	C.C Road	DLC(1:5:10)	10-05-2022	07-06-2022	150x150x150	22500	695	11.4	
3	C.C Road	DLC(1:5:10)	10-05-2022	07-06-2022	150x150x150	22500	698	11.8	

Remarks :



Asst. Executive Engineer
Yelahanka Sub. Division
(BBMP Ynk. Zn)
Yelahanka, Bangalore

Signature

ಕರ್ನಾಟಕ ರಾಜ್ಯ ಸಾರ್ವಜನಿಕ ಕಾರ್ಯಾಚರಣೆ ಮತ್ತು ಸಂಪನ್ಮೂಲ ಇಲಾಖೆ
ಯಂತ್ರ ಸಂಪನ್ಮೂಲ ಸಹಾಯಕ ನಿರ್ದೇಶಕರು
ಜಿ.ಪಿ.ಎಂ.ಓ. ಬೆಂಗಳೂರು-108